

<p style="text-align: center;">TOWNSHIP OF WHITEWATER REGION</p>	<p style="text-align: center;">POLICY NAME: Prevention of Cross Connections at Commercial / Industrial / Institutional / Facilities</p>
<p style="text-align: center;">DEPARTMENT: PUBLIC WORKS</p>	<p style="text-align: center;">DATE ESTABLISHED: July 12th, 2005 IMPLEMENTED</p> <p>DATE REVISED:</p>

The Township of Whitewater Region requires all Commercial, Industrial, and Institutional facilities within the Township of Whitewater Region to have in place Back Flow Prevention on their Municipal water line(s) so as to prevent any contaminated water from flowing back into the municipal distribution system.

1. The back flow prevention equipment must be installed in a fashion so as to allow periodic testing.
2. Each system will be tested by the owner monthly and a record maintained.
3. Records will include Date, Results of Test, Signature of Inspector and Action Required if any. Date the repairs that are completed, and obtain signature of person that makes repairs.
4. A minimum of one yearly inspection shall be conducted by the Township to ensure that items **1**, **2** and **3** are complied with.
5. Failure to comply will result in a fine of up to \$1000.00 payable to the Township of Whitewater Region.

Hal Johnson

Public Works Supervisor
Township of Whitewater Region

APPROVED DATE: May 10th, 2006

Motion Number: 2006-397